



TWF INSTALLATION SEQUENCE FOR BACK / UPPER WALL CONNECTIONS FOR ROOF TO THROUGH WALL FLASHINGS (SOME PARTS HIDDEN FROM VIEW):

1. INSTALL POLYGUARD DECK GUARD HT FROM THE ROOFING DECK TO THE FACE OF BACK / UPPER WALL.
2. INSTALL POLYGUARD DETAILING SEALANT ALONG TOP EDGE OF THE DECK GUARD HT.
3. INSTALL ROOF SHINGLES AND STEP FLASHING ALONG THE BACK / UPPER WALL.
4. FABRICATE AND INSTALL METAL FLASHING FOR EACH DRIP COUNTER STEP FLASHING AND THE DRIP COUNTER THAT BRIDGES THE SADDLE RIDGE WITH A HEIGHT THAT WILL ENGAGE 3/4-INCH OF THE DRIP COUNTER STEP AND DRIP COUNTER EXTERNAL LEGS AND ALLOW ROOM FOR VERTICAL MOVEMENT OF THE METAL FLASHING.

NOTE: FREE THE SURFACES THAT WILL RECEIVE THE FLASHING FROM IRREGULARITIES THAT WOULD INTERFERE WITH A FLAT INTERFACE WITH THE FLASHING, OR POSE A FLASHING PUNCTURE HAZARD. APPLY A COATING OF 650LI, CALIFORNIA SEALANT, GREEN CALIFORNIA SEALANT OR SHUR-TAC WATER-BASED LIQUID ADHESIVE TO CLEAN AND DRY SURFACES THAT WILL BE RECEIVING THE FLASHINGS. BASE SELECTION OF LIQUID ADHESIVE ON SUBSTRATE COMPATIBILITY AND VOC REQUIREMENTS. REFER TO POLYGUARDS PUBLICATION "PRINCIPLES OF WATERPROOFING ABOVE GRADE EXTERIOR WALL ASSEMBLIES" FOR STEP BY STEP INSTALLATION INSTRUCTIONS.

TWF10.5

TWF VENEERS AT WALL TO ROOF INTERSECTION (5 OF 5 FIGURES)

Polyguard Products, Inc.
 P.O. Box 755 - Emms, TX 75119
 Phone: 214-515-5000 Fax: 972-975-9425
 Web Site - www.polyguardproducts.com

Polyguard

© POLYGUARD PRODUCTS, INC. 2010

MATERIALS SEPARATED FOR CLARITY NTS

This literature is provided based on data and knowledge available at the time of printing. Polyguard Products, Inc. and its affiliates do not warrant the accuracy, completeness, or applicability of the information contained herein. Please refer to all applicable codes, specifications, and standards for additional information. Polyguard Products, Inc. and its affiliates do not assume any liability for damages, losses, or expenses in connection with our products or services, which may apply to all goods supplied by us.